

CLAYTON PUBLIC SCHOOL DISTRICT
Office of the Superintendent
350 East Clinton Street, Clayton NJ 08312

Nikolaos C. Koutsogiannis
Superintendent of Schools

Phone: 856-881-8700
Fax: 856-863-8196

April 27, 2017

Dear Clayton Public School District Community:

The NJ state board of education has adopted regulations regarding testing for lead in public school drinking water. In compliance with the Department of Education regulations, Clayton Public School District tested our schools' drinking water for lead. In accordance with the Department of Education regulations, Clayton Public School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 ug/1 (parts per billion [ppb]).

Results of our Testing


Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the Clayton Public School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 74 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 ug/1 [ppb]).

The table below identifies the drinking water outlets that tested above the 15 ug/1 for lead, the actual lead level, and what temporary remedial action Clayton Public School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result In ug/1 (ppb)	Flush Sample Result In ug/1 (ppb)	Remedial Action
Training Room Hose Bib	22.5	Less than 2.0	Faucet is out of service until replacement or remediation.

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 9 a.m. and 4 p.m. and are also available on our website at www.claytonps.org. For more information about water quality in our schools, contact Charles D. Schriver, III, Facilities Director, at Clayton Public School District, 350 East Clinton Street, Clayton, NJ 08312. 856-863-0525.

Sincerely yours,



Nick Koutsogiannis
Superintendent of Schools
Clayton Public School District

NK/rml